

Endt: No. 63097/59/H3

Municipal Office, Coimbatore,  
Dt. 7-6-61.

Copy of Director of Town Planning's letter L.Dis No. 7716/60/AS dated 21-7-60 is communicated to all clerks, Asst: Town Planning Officers, Building Inspectors for information.

*B. Anand*  
12-6-61

For Commissioner.

srv 9-6-a

..  
Copy of L.Dis No. 7716/60/AS d/-21-7-60 of the Director of Town Planning, Madras to the Commissioner, Coimbatore Municipality.

...  
Sub:- Town Planning - Coimbatore Municipality - construction of a godown and Kalyanamandapam in T.S.No. 3/1750 and 1751/1 and 2 Rangai Gounder St., - non-Town Planning area - applicability of Rule 9(4) to 9(6) of Revised Building Rules - clarification - reg:

Ref:- Your letter No. 63097/59 d/-27-4-60.

....  
In view of the fact that the ground floor structure is to be exclusively used as a godown the Rules 9(4) to 9(6) of Building Rules will not be applicable. But in the case of first and second floor which are to be used as Kalyanamandapam (i.e) intended to be used for purposes of human habitation, the rules 9(4) to 9(6) of Building Rules have to be enforced. The calculation of open spaces requirements should be done at the respective floor levels as specified under Rule 9(10) of the Building Rules.

The plans received with your letter are returned herewith.  
Encl:- 3 Plans.

srv 9-6-a

/True copy/

Sd....  
For Director of Town Planning.